

**CUSTOMER ASSISTANCE GUIDE  
BUILDING PERMIT APPLICATION SUBMITTAL REQUIREMENTS**

**SWIMMING POOLS (IN-GROUND OR ABOVE-GROUND),  
SPAS AND HOT TUBS (CONTAINS WATER OVER 24 INCHES DEEP)**

- Please read all of the following information.
- The following is a check list. You must have a "checkmark" in all the sections listed below prior to submitting your application.

- \_\_\_\_\_ "Affidavit of Exemption" (See attached form) If you are hiring a contractor to construct your pool, and they have workers' compensation, have the contractor or their insurance carrier provide us with a "Certificate of Insurance" showing proof of such. If the homeowner or a contractor without workers' compensation is constructing the pool, the attached form must be completed and notarized.
- \_\_\_\_\_ A site plan showing the proposed pool, hot tub or spa location including the distances in feet, to the front, sides and rear property lines.
- \_\_\_\_\_ Three (3) sets of complete construction documents that show in detail code compliance for all of the work proposed to include but not limited to the following information;
- \_\_\_\_\_ Safety barrier – show type for your specific pool installation, (fence, walls, etc.) including height. (Barrier requirements attached).
  - \_\_\_\_\_ If installing deck at pool – take submittal requirements for deck also.
  - \_\_\_\_\_ Electrical service (pump, filter, receptacles, etc.) show location and type of wiring method. (Electrical requirements attached).
- \_\_\_\_\_ Completed building permit application.

MDIA will review plans submitted to determine code compliance. If the minimum submittal requirements are not met, we will ask the applicant to supply additional information. If the minimum requirements are met, the plans will be marked "approved". A building permit will be issued and the applicant will be notified of the inspection fees and when they can pick-up the permit at the Municipal Building. All fees shall be paid prior to the issuance of the permit. Then use the inspection procedures provided to have all of the required inspections performed.

## **INSPECTION PROCEDURES SWIMMING POOLS, SPAS AND HOT TUBS**

- Building permit must be posted on the site of the work and clearly visible from the road until completion of the project.
- Your approved plans must be available at all times for inspections. These are the plans that were submitted with your application and were marked "Approved" by the Building Code Official.
- The permit applicant or authorized agent is responsible for scheduling all inspections.
- **DO NOT schedule an inspection if the work is not ready!!!!**
- When scheduling an inspection, you must supply your permit number to the inspector.

### **MINIMUM OF 24 HOUR NOTICE REQUIRED TO MIDDLE DEPARTMENT INSPECTION AGENCY, INC.**

#### **ALL POOLS:**

1. Electrical Inspection – A. Bonding all metal parts (rebar if concrete, ladder, etc) associated with pool prior to placing concrete. B. Underground to be inspected prior to cover.  
**Inspector, Clyde Volk** **Phone, 1-800-662-6342**
  
2. If Installing Deck Around Or Next To Pool – Use inspection procedure for decks also.  
**Inspector, Clyde Volk** **Phone, 1-800-662-6342**
  
3. Safety Barrier Inspection – Done prior to filling pool with water.  
**Inspector, Clyde Volk** **Phone, 1-800-662-6342**
  
4. Final Electrical  
**Inspector, Clyde Volk** **Phone, 1-800-662-6342**
  
5. Final Inspection – When job is completely finished, prior to occupancy permit and after electrical inspection.  
**Inspector, Clyde Volk** **Phone, 1-800-662-6342**

## APPENDIX G

# SWIMMING POOLS, SPAS AND HOT TUBS

*(The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.)*

### SECTION AG101 GENERAL

**AG101.1 General.** The provisions of this appendix shall control the design and construction of swimming pools, spas and hot tubs installed in or on the *lot* of a one- or two-family dwelling.

**AG101.2 Pools in flood hazard areas.** Pools that are located in flood hazard areas established by Table R301.2(1), including above-ground pools, on-ground pools that involve placement of fill, shall comply with Sections AG101.2.1 or AG101.2.2.

**Exception:** Pools located in riverine flood hazard areas which are outside of designated floodways.

**AG101.2.1 Pools located in designated floodways.** Where pools are located in designated floodways, documentation shall be submitted to the *building official*, which demonstrates that the construction of the pool will not increase the design flood elevation at any point within the *jurisdiction*.

**AG101.2.2 Pools located where floodways have not been designated.** Where pools are located where design flood elevations are specified but floodways have not been designated, the applicant shall provide a floodway analysis that demonstrates that the proposed pool will not increase the design flood elevation more than 1 foot (305 mm) at any point within the *jurisdiction*.

### SECTION AG102 DEFINITIONS

**AG102.1 General.** For the purposes of these requirements, the terms used shall be defined as follows and as set forth in Chapter 2.

**ABOVE-GROUND/ON-GROUND POOL.** See "Swimming pool."

**BARRIER.** A fence, wall, building wall or combination thereof which completely surrounds the swimming pool and obstructs access to the swimming pool.

**HOT TUB.** See "Swimming pool."

**IN-GROUND POOL.** See "Swimming pool."

**RESIDENTIAL.** That which is situated on the premises of a detached one- or two-family dwelling or a one-family *town house* not more than three stories in height.

**SPA, NONPORTABLE.** See "Swimming pool."

**SPA, PORTABLE.** A nonpermanent structure intended for recreational bathing, in which all controls, water-heating and water-circulating *equipment* are an integral part of the product.

**SWIMMING POOL.** Any structure intended for swimming or

2009 INTERNATIONAL RESIDENTIAL CODE®

recreational bathing that contains water over 24 inches (610 mm) deep. This includes in-ground, above-ground and on-ground swimming pools, hot tubs and spas.

**SWIMMING POOL, INDOOR.** A swimming pool which is totally contained within a structure and surrounded on all four sides by the walls of the enclosing structure.

**SWIMMING POOL, OUTDOOR.** Any swimming pool which is not an indoor pool.

### SECTION AG103 SWIMMING POOLS

**AG103.1 In-ground pools.** In-ground pools shall be designed and constructed in conformance with ANSI/NSPI-5 as listed in Section AG108.

**AG103.2 Above-ground and on-ground pools.** Above-ground and on-ground pools shall be designed and constructed in conformance with ANSI/NSPI-4 as listed in Section AG108.

**AG103.3 Pools in flood hazard areas.** In flood hazard areas established by Table R301.2(1), pools in coastal high hazard areas shall be designed and constructed in conformance with ASCE 24.

### SECTION AG104 SPAS AND HOT TUBS

**AG104.1 Permanently installed spas and hot tubs.** Permanently installed spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-3 as listed in Section AG108.

**AG104.2 Portable spas and hot tubs.** Portable spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-6 as listed in Section AG108.

### SECTION AG105 BARRIER REQUIREMENTS

**AG105.1 Application.** The provisions of this chapter shall control the design of barriers for residential swimming pools, spas and hot tubs. These design controls are intended to provide protection against potential drownings and near-drownings by restricting access to swimming pools, spas and hot tubs.

**AG105.2 Outdoor swimming pool.** An outdoor swimming pool, including an in-ground, above-ground or on-ground pool, hot tub or spa shall be surrounded by a barrier which shall comply with the following:

1. The top of the barrier shall be at least 48 inches (1219 mm) above *grade* measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches (51 mm) measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an above-ground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure.

Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be 4 inches (102 mm).

2. Openings in the barrier shall not allow passage of a 4-inch-diameter (102 mm) sphere.
3. Solid barriers which do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.
4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed 1 3/4 inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1 3/4 inches (44 mm) in width.
5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing between vertical members shall not exceed 4 inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1 3/4 inches (44 mm) in width.
6. Maximum mesh size for chain link fences shall be a 2 1/4 inch (57 mm) square unless the fence has slats fastened at the top or the bottom which reduce the openings to not more than 1 3/4 inches (44 mm).
7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than 1 3/4 inches (44 mm).
8. Access gates shall comply with the requirements of Section AG105.2, Items 1 through 7, and shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Gates other than pedestrian access gates shall have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from the bottom of the gate, the release mechanism and openings shall comply with the following:
  - 8.1. The release mechanism shall be located on the pool side of the gate at least 3 inches (76 mm) below the top of the gate; and
  - 8.2. The gate and barrier shall have no opening larger than 1/2 inch (12.7 mm) within 18 inches (457 mm) of the release mechanism.
9. Where a wall of a *dwelling* serves as part of the barrier, one of the following conditions shall be met:
  - 9.1. The pool shall be equipped with a powered safety cover in compliance with ASTM F1346; or
  - 9.2. Doors with direct access to the pool through that wall shall be equipped with an alarm which produces an audible warning when the door and/or its screen, if present, are opened. The alarm shall be listed in *and labeled* in accordance with UL 2017. The deactivation switch(es) shall be located at least 54 inches (1372 mm) above the threshold of the door; or

2009 INTERNATIONAL RESIDENTIAL CODE®

#### Appendix G

- 9.3. Other means of protection, such as self-closing doors with self-latching devices, which are *approved* by the governing body, shall be acceptable as long as the degree of protection afforded is not less than the protection afforded by Item 9.1 or 9.2 described above.
10. Where an above-ground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps:
  - 10.1. The ladder or steps shall be capable of being secured, locked or removed to prevent access; or
  - 10.2. The ladder or steps shall be surrounded by a barrier which meets the requirements of Section AG105.2, Items 1 through 9. When the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a 4-inch-diameter (102 mm) sphere.

**AG105.3 Indoor swimming pool.** Walls surrounding an indoor swimming pool shall comply with Section AG105.2, Item 9.

**AG105.4 Prohibited locations.** Barriers shall be located to prohibit permanent structures, *equipment* or similar objects from being used to climb them.

**AG105.5 Barrier exceptions.** Spas or hot tubs with a safety cover which complies with ASTM F 1346, as listed in Section AG107, shall be exempt from the provisions of this appendix.

#### SECTION AG106

##### ENTRAPMENT PROTECTION FOR SWIMMING POOL AND SPA SUCTION OUTLETS

**AG106.1 General.** Suction outlets shall be designed and installed in accordance with ANSI/APSP-7.

#### SECTION AG107 ABBREVIATIONS

##### AG107.1 General.

ANSI-American National Standards Institute  
11 West 42<sup>nd</sup> Street  
New York, NY 10036

APSP-Association of Pool and Spa Professionals  
NSPI-National Spa and Pool Institute  
2111 Eisenhower Avenue  
Alexandria, VA 22314

ASCE-American Society of Civil Engineers  
1801 Alexander Bell Drive  
Reston, VA 98411-0700

ASTM-ASTM International  
100 Barr Harbor Drive  
West Conshohocken, PA 19428

UL-Underwriters Laboratories, Inc.  
333 Pfingsten Road  
Northbrook, IL 60062-2096

**SECTION AG108  
STANDARDS**

**APPENDIX G**

**AG108.1 General.**

**ANSI/NSPI**

ANSI/NSPI-3-99 Standard for  
Permanently Installed Residential Spas.....AG104.1

ANSI/NSPI-4-99 Standard for Above-ground/  
On-ground Residential Swimming Pools.....AG103.2

ANSI/NSPI-5-2003 Standard for  
Residential In-ground Swimming Pools.....AG103.1

ANSI/NSPI-6-99 Standard for  
Residential Portable Spas.....AG104.2

**ANSI/APSP**

ANSI/APSP-7-06 Standard for Suction Entrapment  
Avoidance in Swimming Pools, Wading Pools, Spas,  
Hot Tubs and Catch Basins.....AG106.1

**ASCE**

ASCE/SEI-24-05 Flood Resistant  
Design and Construction.....AG103.3

**ASTM**

ASTM F 1346-91 (2003) Performance  
Specification for Safety Covers and Labeling  
Requirements for All Covers for Swimming Pools,  
Spas and Hot  
Tubs.....AG105.2,AG105.5

**UL**

UL 2017-2000 Standard for General-purpose  
Signaling Devices and Systems-with Revisions  
Through June 2004.....AG105.2

**2009 INTERNATIONAL RESIDENTIAL CODE®**

# TYPICAL WIRING DIAGRAM FOR AN ABOVE-GROUND POOL SHOWING CODE REQUIRED METHODS AND EQUIPMENT

METAL LADDER OR ANY METAL WITHIN 5 FEET OF INSIDE WALL OF POOL SHALL BE BONDED.

A PERIMETER SURFACE BONDING GRID SHALL BE INSTALLED TO INCLUDE PAVED AND UNPAVED WALKING SURFACES FOR 3 FEET HORIZONTALLY BEYOND THE INSIDE WALLS OF THE POOL AND SHALL BE ATTACHED AT 4 POINTS HORIZONTALLY SPACED AROUND THE PERIMETER OF THE POOL. THIS SHALL CONSIST OF EITHER STRUCTURAL REINFORCING STEEL OR A MINIMUM #8 BARE SOLID COPPER CONDUCTOR FOLLOWING THE CONTOUR OF THE POOL BETWEEN 65-24 INCHES FROM THE INSIDE WALLS OF THE POOL. THE CONDUCTOR SHALL BE SECURED WITHIN OR UNDER THE PERIMETER SURFACE 4-6 INCHES BELOW THE SURGRADE.

#8 A.W.G. SOLID COPPER BONDING CONDUCTOR CONNECTED TO UPRIGHTS OF POOL AND METAL LADDERS(S).

GFCI PROTECTED WEATHERPROOF CONNECTOR FOR COND.

WEATHERPROOF "IN USE" (BUBBLE) COVER.

6/4 POST, PRESSURE TREATED, SET IN CONCRETE OR OTHER APPROVED SUPPORT.

SCHEDULE 40 OR 80 P.V.C., R.G.S., NEC CONDUIT, CONDUCTORS RATED FOR WET LOCATION

INTENTIONAL BOND OF APPROX. 9 SQ. IN. CONDUCTIVE SURFACE AREA SHALL BE INSTALLED IN CONTACT WITH POOL WATER

IECC 401.10.2 TIME SWITCH SHALL BE INSTALLED ON POOL HEATER AND PUMP.

POOL

POOL FILTER

TRAVIS COND.

BONDING LUGS

GFCI protected 20 amp, 120V single (not duplex) receptacle and plug with weatherproof "in-use" "extra duty" (bubble) cover.


6 FEET

## NOTE:

For wiring supplying pool pump motor, Type NM and UF cable is permitted only for use within dwelling.

## LUG DETAIL

HOUSE



**THIS FORM REQUIRES A NOTARY SEAL**

**AFFIDAVIT OF EXEMPTION**

The undersigned affirm that he/she is not required to provide workers compensation insurance under the provisions of Pennsylvania's Workers' Compensation Law for one of the following reasons, as indicated:

- \_\_\_\_\_ Property owner performing own work. If property owner does hire contractor to perform any work pursuant to building permit, contractor must provide proof of workers' compensation insurance to the municipality. Homeowner assumes liability for contractor compliance with this requirement.
  
- \_\_\_\_\_ Contractor has no employees. Contractor prohibited by law from employing any individual to perform work pursuant to this building permit unless contractor provides proof of insurance to the municipality.
  
- \_\_\_\_\_ Religious exemption under the Workers' Compensation Law. All employees of contractor are exempt from workers' compensation insurance (attach copies of religious exemption letter for all employees).

\_\_\_\_\_  
Signature of Applicant

County of \_\_\_\_\_

Municipality of \_\_\_\_\_

Subscribed, sworn to and acknowledged  
before me by the above \_\_\_\_\_  
this \_\_\_\_\_ Day of \_\_\_\_\_  
20 \_\_\_\_\_.

**SEAL**

\_\_\_\_\_  
**Notary Public**